



**CEIDEN**


PLATAFORMA TECNOLÓGICA DE ENERGÍA NUCLEAR DE FISIÓN

**IDOM**



IDOM Experiences with the Databases ICSBEP,  
SINBAD & SFCOMPO

# IDOM Nuclear Services in the world



MORE THAN:

**400**  
people  
having participated  
in nuclear projects

**+400**  
projects

Over  
**40**  
years

**26**  
countries


**#8**  
in international nuclear  
engineering design ranking

\*ENR Global Sourcebook 2021

Spain, UK, Slovenia, Slovakia, Bulgaria, Ukraine, Lithuania, Finland, China, Mexico, Bolivia, Brazil, Argentina, Chile, Colombia, Belgium, Netherlands, Israel, Sweden, Emirates, Canada, France, Turkey, Czech Republic, Saudi Arabia, Croatia.

# IDOM Nuclear Services

## Main Business Lines



# Main Stakeholders

IDOM has worked together with the main players in the international nuclear ecosystem

## Governments, Public Organizations & Agencies



## Nuclear Owners, Operators & WMOs



## Nuclear Supply Chain & Vendors



# IDOM Experiences with the Databases ICSBEP, IRPHEP, SINBAD y SFCOMPO

- Training & learning
- Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

**Replicate benchmark  
experiment in simulations**

- Study effects of technological uncertainties on the validation of CODE: Modelling and analysis of samples from ARIANE program (SFCOMPO)

**Source of Information**

# Training & Learning

Replicate benchmark  
experiment simulations

HEU-MET-FAST-002




Figure 1. Topsy with Tuballoy Tamper Assembly.






Table 7.a. Sample Calculations Results (United States).

Representation	KENO (16-group Hansen-Roach)	KENO (27-group SCALE ENDF/B-IV)	MCNP (Continuous Energy ENDF/B-V)	TWODANT (27-group SCALE ENDF/B-IV)
Sphere	0.9945 ± 0.0008	1.0075 ± 0.0009	1.0024 ± 0.0011	1.0083
Cylinder	0.9973 ± 0.0007	1.0082 ± 0.0009	1.0030 ± 0.0010	1.0079
4 x 4 x 3.66 Inch Parallelepiped	0.9938 ± 0.0007	1.0050 ± 0.0008	1.0020 ± 0.0010	NA
5 x 5 x 2.53 Inch Parallelepiped	0.9922 ± 0.0007	1.0045 ± 0.0009	1.0041 ± 0.0010	NA
3 x 3 x 7.56 Inch Parallelepiped	0.9933 ± 0.0007	1.0094 ± 0.0009	1.0039 ± 0.0010	NA
3 x 3.5 x 6 Inch Parallelepiped	0.9952 ± 0.0007	1.0035 ± 0.0010	1.0028 ± 0.0011	NA

# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database



Replicate benchmark  
experiment in simulations

# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

References provided with the Benchmark:

- Benchmark specifications in html format
- MCNP Inputs
- Final Report

## SINBAD ABSTRACT [NEA-1553/55](#)

### FNG-ITER DOSE RATE EXPERIMENT

```

1 message: ip
2
3 DOSE RATE EXPERIMENT
4 c Neutron transport - IRRADIATION MODEL
5 c cup di rame
6 1 3 -8.94 6 (1:7) -2 -8
7 c gap di acqua cilindrico
8 2 2 -1.0 6 8 -2 -9

```

### EXPERIMENTAL VALIDATION OF SHUT-DOWN DOSE RATES

Replicate benchmark  
experiment in simulations



# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

## Materials

- Small discrepancies in the compositions given
- Discrepancies in the impurities considered
- Composition of Nickel activation foils not defined

**Replicate benchmark  
experiment in simulations**

Element	wt% cor	Element	wt% content Reference [2]	wt% content MCNP input files [2]	wt% content
	Reference	B	0.005	0.005	0.005
B	0.003	C	0.03	0.03	0.03
C	0.04	Al	-	-	<0.03
Si	0.45	Si	0.69	0.69	0.69
P	0.02	P	0.021	0.021	0.021
S	0.00	S	0.006	0.006	<0.01
V	0.16	V	0.12	0.04	0.12
Cr	16.8	Cr	17.8	17.81	17.8
Mn	1.14	Mn	1.64	1.64	1.64
Fe	68.3	Fe	66.223	66.23	66.22
Co	0.14	Co	0.07	0.07	0.07
Ni	10.7	Ni	11.3	11.3	11.3
Cu	0.09	Cu	0.09	0.09	0.09
Mo	2.12	As	-	-	<0.01
Sn	0.00	Zr	-	-	<0.03
Pb	0.00	Nb	-	0.011	<0.01
Total	99.99	Mo	2	2	2
		Sn	0.004	0.004	<0.01
		Ti	-	-	<0.01
		Pb	0.001	0.001	<0.01
		Total	100	99.948	

Table A1-9: Comparison of chemical composition of stainless steel AISI-316 except the fifth one between reference [2], MCNP input files and reference [8].

Table A1-10: Comparison of chemical composition of stainless steel AISI-316 except the fifth one between reference [2], MCNP input files and reference [8].


Table A1-11: Comparison of chemical composition of stainless steel AISI-316 used for the fifth layer, m10 between reference [2], MCNP input files and reference [8].

# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

## Geometry

- Position and thickness of Layer 5

This discrepancy may come from the fact that when the 2-mm thick bottom and lateral walls, and the additional coating surrounding cavity center had been added, the position of layer number 5 has not been adjusted to this new configuration.



Material	Thickness [cm]	Location on the y-axis [cm]
-----		
-First part (100 cm x 100 cm cross-section):		
SS316	4.35	5.6 ... 9.95
SS316	4.65	9.95 ... 14.6
Perspex	2.06	14.6 ... 16.66
SS316	4.65	16.66 ... 21.31
Perspex	2.06	21.31 ... 23.37
SS316	4.60	23.37 ... 27.97
SS316	7.70	27.97 ... 35.67 fifth layer
SS316	4.90	35.67 ... 40.57
SS316	4.17	40.57 ... 44.74
Perspex	2.06	44.74 ... 46.8
SS316	4.95	46.8 ... 51.75
Perspex	2.06	51.75 ... 53.81
SS316	4.80	53.81 ... 58.61
Perspex	2.06	58.61 ... 60.67
SS316	4.80	60.67 ... 65.47
Perspex	2.06	65.47 ... 67.53
SS316	4.90	67.53 ... 72.43
SS316	5.00	72.43 ... 77.43

```

90 py 25.3
c -----
c   piano per definire una parete interna scatola
91 py 28.17
c -----
c   piani limite del blocco perspex - ss

```

# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

## Geometry

- Nickel Activation foils:
  - Small discrepancies on foil 3 thickness
- TLD detectors
  - Discrepancies on TLD 3 radius

Replicate benchmark  
experiment in simulations





Figure 5-6: Central cavity and Ni activation foils on cavity walls (XY view).






Figure 5-8: G-M detector in cavity center and TLD detectors located all around cavity walls.

# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

## Source

- Routines *source.f* in MCNP5/X format not compatible with MCNP 6.2



Replicate benchmark  
experiment in simulations

# Support to CODE validation: modeling and analysis of the FNG-ITER Benchmark of SINBAD database

## Materials

- Small discrepancies in the compositions given
- Discrepancies in the impurities considered
- **Composition of Nickel activation foils not defined**

## Geometry

- Position and thickness of Layer 5
- Nickel Activation foils:
  - Small discrepancies on foil 3 thickness
- TLD detectors
  - Discrepancies on TLD 3 radius

## Source

- **Routines *source.f* in MCNP5/X format not compatible with MCNP 6.2**

**Obtaining results in agreement with the benchmark is difficult mainly due to the source definition**

# Study effects of technological uncertainties on the validation of CODE: Modelling and analysis of samples from ARIANE program (SFCOMPO)

## Sample ARIANE-GU3

- All necessary data obtained from *SFCOMPO* and/or *ARIANE program final report*
- Typical uncertainties and manufacturing tolerances obtained from *SFCOMPO Evaluation Guide*
- XS libraries:
  - JEFF-3.1
  - JEFF-3.2
  - ENDF/B-VII.0
  - ENDF/B-VII.1

Parameter	Uncertainty/tolerance
Fuel pellet diameter	± 20 µm
Fuel pellet density	± 1 %
Enrichment ( <sup>235</sup> U wt%)	± 0.05 %
Core power	± 2 %
Water moderator density	± 0.005 g/cm <sup>3</sup>
Boron content in water	± 10 ppm
Water moderator temperature	± 2° C
Fuel temperature	± 100° C

Table 6-1: Values of typical uncertainties extracted from [3]

Type	PWR	
Name	Gösgen	
Country	Switzerland	
Total number of assemblies	177	
Thermal power	3002	MW
Electric power	1020	MW
Fuel type	UO <sub>2</sub>	
235U/U	4.1	%
Pu/U+Pu	-	%
Gd2O3/oxide	-	%
Active fuel length	355.0	cm
Fuel density	10.4	g/cm <sup>3</sup>
Estimated sample burn up	52.5	MWd/kg <sub>HM</sub>
Lattice type	15 x 15	
Assembly pitch	21.58	cm
Pin pitch	1.43	cm
Fuel pins	205	
Guide tubes	20	
Instrumentation tubes	0	
Guide tube material	Zr-4	
Guide tube outer radio	0.89	cm
Guide tube inner radio	0.82	cm
Cladding material	Zr-4	
Cladding outer radio	0.5375	cm
Cladding inner radius	0.485	cm
Pellet radius	0.4555	cm
Central gap	-	

Table 5-2: Overview of the characteristics of the ARIANE.GU3 sample.

Cycle	Core periphery	Neighbor assembly type	Start date	End date
16	No	-	June 29, 1994	June 10, 1995
17	No	-	July 05, 1995	June 08, 1996
18	No	-	June 30, 1996	June 07, 1997

Table 5-3: Operational cycles for the ARIANE.GU3 sample

Source of Information

# Study effects of technological uncertainties on the validation of CODE: Modelling and analysis of samples from ARIANE program (SFCOMPO)

## ◎ Sample ARIANE-GU3

- All necessary data obtained from *SFCOMPO* and/or *ARIANE program final report*
- Typical uncertainties and manufacturing tolerances obtained from *SFCOMPO Evaluation Guide*
- XS libraries:
  - JEFF-3.1
  - JEFF-3.2
  - ENDF/B-VII.0
  - ENDF/B-VII.1

Source of Information


Parameter	pcm difference		Inside 3 $\sigma$
	minimum	maximum	
Fuel pellet diameter	0	150	yes
Fuel pellet density	0	150	yes
Enrichment	200	400	no
Power	0	600	no
Water density	0	200	no
Boron content	0	200	no
Water moderator temperature	0	100	yes
Fuel temperature	0	400	no

Table 8-1: Results of ARIANE GU3 sample

# Final Remarks

**Benchmark databases are a good tool,  
not only for replicating the benchmark for code validation,  
also are a good source of exercises  
and information in general**

**While ICSBEP & SFCOMPO are very well structured,  
SINBAD database seems to have more contradicting information**





IDOM

Muchas Gracias